

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1230163

Product: Equipotential terminal block

Type: EPS 2

Rating: conductor 2,5 - 95 mm² Cu, 2,5 - 95 mm² Al,
type conductor 20 x 3 mm a 30 x 4 mm FeZn

Ordering firm: Elektro, výrobní družstvo v Bečově nad Teplou
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Manufacturer: Elektro, výrobní družstvo v Bečově nad Teplou
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 231013-01/01 of: 27.04.2023

A sample of the product was found to be in conformity with:
ČSN EN 60947-7-1 ed. 3:10 cl. 5.1, 8.3.2, 8.3.3.1, 8.3.3.2, 8.3.3.3, 8.3.3.4, 8.4.5, 8.4.6, 8.5

Other data:

The validity of the certificate is limited to: 01.05.2026

02.05.2023

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



231013-01