

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lísem 129/2, Troja, 182 00 Praha 8

## CERTIFICATE

No.: 1240008

**Product:** Fuse clamps + linking comb

**Type:** RSP 4, RSP 4 LED, RSP 4 LED 24 – 48 V + HP-RSP4

**Rating:** 6,3 A/250 V; 6,3 A/24-48 V; U<sub>i</sub>: 400 V; comb I<sub>n</sub>: 32 A

**Ordering firm:** Elektro, výrobní družstvo v Bečově nad Teplou  
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

**Manufacturer:** Elektro, výrobní družstvo v Bečově nad Teplou  
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 240002-01/01 of: 09.01.2024

**A sample of the product was found to be in conformity with:**  
ČSN EN 60947-7-3 ed. 2:10

**Other data:**

**The validity of the certificate is limited to:** 10.01.2027

11.01.2024

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



240002-01