

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Terminal block

Name and address of the applicant

Elektro, výrobní družstvo v Bečově nad Teplou
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Name and address of the manufacturer

Elektro, výrobní družstvo v Bečově nad Teplou
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Name and address of the factory

Elektro, výrobní družstvo v Bečově nad Teplou
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

35 mm², U_i = 1000 V AC/1500 V DC, U_{imp} = 8 kV

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

RSA PE 35A

Additional information (if necessary may also be reported on page 2)

Amendment M1: 07.04.2025

The rated insulation voltage was extended to the value 1500 V DC and the rated impulse withstand voltage was increased to a value 8 kV.

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-7-2:2009


As shown in the Test Report Ref. No. which forms part of this Certificate

302528-01/01 of: 30.05.2014,
302825-01/01-M1 of: 30.05.2025

This CB Test Certificate is issued by the National Certification Body

Elektrotechnický zkušební ústav, s. p.
Pod lisem 129/2, Troja, 182 00 Praha 8
Czech Republic

Date: 06.06.2014 corr.08.04.2025

Miroslav Sedláček
Certification and Inspection Manager

**IEC****IECEE**

Test Report issued under the responsibility of:

ezú elektrotechnický
zkušební
ústav**TEST REPORT****IEC 60947-7-2****Low-voltage switchgear and controlgear****Part 7: Ancillary equipment****Section Two: Protective terminal blocks for copper conductors**

Report Number.....: 302528-01/01-M1

Date of issue.....: 30. 5. 2014; Amendment M1: 7. 4. 2025

Total number of pages 10

Name of Testing Laboratory
preparing the Report: Elektrotechnický zkušební ústav, s. p.

Applicant's name: Elektro, výrobní družstvo v Bečově nad Teplou

Address.....: Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Test specification:

Standard.....: IEC 60947-7-2:2009 (Third Edition)

Test procedure: CB Scheme

Non-standard test method: N/A

Test Report Form No.: IEC60947_7_2B

Test Report Form(s) Originator: DEKRA Certification B.V.

Master TRF: Dated 2016-01

Copyright © 2016 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.